



BA-PHALABORWA MUNICIPALITY

- Budget and Treasury -

Procurement and Stores

TO : Prospective Service Provider
FROM : SCM /STORES
DATE : 31 /10/2019
ENQUIRIES : STORES
TELEPHONE : 015 780 6479/6362/61
REF : 134299

Kindly furnish this office with a written quotation for supply of goods/ services as detailed below. The quotation must be submitted on the letterhead of your Entity and delivered at our offices 3 Nyala Street, Phalaborwa not later than 07/11/2019 at 12H00. Attention: Procurement

QUANTITY	Description	PRICE/UNIT (Inc .VAT)	DELIVERY PERIOD
5	Steel Streetlight Poles as per attached specification		

Please number your quotes (Your Ref no)

The following conditions will apply:

- *Price (s) quoted must be valid for at least thirty (30) days from date of your offer.*
- *The municipality retains the prerogative to reject any quotes it deems to be excessive and/or underquoted*
- *A firm delivery period must be indicated.*
- **Original Tax Clearance Certificate**
- **Registered with CIPRO (CK 1 or 2 document)**
- **BBBEE Certificate certified by a SANAS accredited institution or certified sworn affidavit.**
- **Fill in and Return the Declaration of Interest Form (MBD4 Form) obtainable from our website.**
- **Registered on the Centralised Suppliers Database (CSD Report)**
- **Goods to be delivered within 30 days of purchase order**



BA-PHALABORWA MUNICIPALITY

- Budget and Treasury -

Procurement and Stores

STREET LIGHTING POLES

1 GENERAL

The poles shall be constructed of steel, designed fully in accordance with SABS 0225 and shall be fully hot dip galvanised in accordance with the requirements of SABS 763.

The galvanising shall be applied to all parts by a hot-dip process to give a zinc coating of not less than 600 grams per square metre of surface. The zinc coating shall be smooth, clean, of uniform thickness and free from defects.

All drilling, punching, cutting, bending or part shall be completed and all burrs removed before galvanising.

No drilling, welding etc., shall be done to any part which is already galvanised.

Contractors shall note that any galvanised part can be rejected on site if found to be below standard.

The tenderers shall allow for and arrange SABS inspection of all galvanising. Copies of the inspection certificates shall be submitted.

The streetlight fittings shall be mounted on top of a galvanised steel pole with 7.2m mounting height. The poles shall be planted at least 1000mm deep, and 1,2m behind the curb.

The pole shall be indelibly marked with the pole number at 2m height.

All poles will have a top outside diameter of 74 - 76mm. No tolerances greater than this will be acceptable.

The streetlights are fed from the streetlight circuit by means of a 6mm² split concentric cable, looped from pole to pole.

The internal wiring shall be 1,5mm² PVC conductors.

Each pole shall be fitted with the electrical equipment as scheduled in Clause 2.7.3.

2 Electrical requirements

The equipment installed in the pole shall be:-

- 1 - 5A QSM MCB
- 1 - Neutral Bar - 4 way
- 1 - Earth

1 - Removable Gland Plate, suitable for type of cables used. (3 glands)

The internal wiring: 1,5mm² PVC conductors.