



BA-PHALABORWA MUNICIPALITY
MEMORANDUM
- BUDGET AND TREASURY –

TO : *Prospective Service Provider*
FROM : *SCM /STORES*
DATE : *27/05/2021*
ENQUIRIES : *STORES*
TELEPHONE : *015 780 6362/61*
REF : *138766*

Kindly furnish this office with a written quotation for supply of goods/ services as detailed below. The quotation must be submitted on the letterhead of your Business and Brought to our offices 3 Nyala Street, Phalaborwa not later than **04/06/2021 12H00**

QUANTITY	Description	PRICE/UNIT (Inc. VAT)	DELIVERY PERIOD
3	REMOVE & INSTALL 3X24000 BTU AIRCONS @ LICENSING		
1	REMOVE & INSTALL 1X18000 BTU @ LIBRARY		
1	REMOVE @ INSTALL 1X24000 BTU AIRCON @ LICENCE EXAM ROOM		

Please number your quotes (Your Ref no)

The following conditions will apply:

- *Price (s) quoted must be valid for at least thirty (30) days from date of your offer.*
- *The municipality retains the prerogative to reject any quotes it deems to be excessive*
A firm delivery period must be indicated.
- *Tax Clearance Certificate*
- *A service provider be registered with central supplier database (CSD)*
- *Registered with CIPRO (CK 1 or 2 document)*
- *BBBEE Certificate certified by a SANAS accredited institution.*
- *Completed MBD4 (Declaration of Interest) Form*
- *COMPLETE MBD6.2*

SPECIFICATIONS FOR INVERTER AIR CONDITIONERS AS PER THE RAF.

4 X 22,000 btu to 24,000 btu Inverter split unit airconditioners:

- a. Cooling and Heating capacity
- b. Energy efficiency cooling (w/w) of less than 3,5 w/w.
- c. Energy efficiency heating (w/w) of less than 3.75 w/w.
- d. Power consumption cooling of less than 2500 w.
- e. Power consumption heating of less than 2500 w.
- f. Operating current cooling and heating of less than 10 A.
- g. R410A reffridgerant usage (inverter type)
- h. Moisture removal equal or better than 2 l per h i Ambient cooling level of 182 to 45Q C.
- i. Horizontal and vertical air direction control.
- k. Indoor temp. display 24 hour timer.
- m. Auto restart.
- n. Auto mode.
- o. Fasty cool.
- p. Dehumidification.
- q. Minimum 10 year warranty on compressor.
- r. Minimum 5 year warranty on electronics (parts)
- s. Software connection for laptop aided diagnostics etc.
- t. Contractor to be an accredited agent or an accredited installer fully accredited with the supplier of the particular make to instal, service or repair the units purchased.
- u. Removal of existing units to be included and delivered to the SCM stores
- v. Back to back installation to be included.

1 x 18,00 btu Inverter split unit air conditioners:

- a. Cooling and Heating capacity
- b. Energy efficiency cooling (w/w) of less than 3,5 w/w.
- c. Energy efficiency heating (w/w) of less than 3.75 w/w.
- d. Power consumption cooling of less than 1 800 w.
- e. Power consumption heating of less than 1800 w.
- f. Operating current cooling and heating of less than 10 A.
- g. R410A reffridgerant usage (inverter type)
- h. Moisture removal equal or better than 2 l per h
- i. Ambient cooling level of at least 182 to 40Q C. i. J.Horizontal and vertical air direction control.
- k. Indoor temp. display. l. 24 hour timer.
- m. Auto restart.
- n. Auto mode.
- O. Fasty cool
- p. Dehumidification.
- q. Minirfium 10 year warranty on compressor.
- r. Minimum 5 year warranty on electronics (parts) S.Software connection for laptop aided diagnostics etc..
- t. Contractor to be an accredited agent or an accredited installer fully accredited with the supplier of the particular make to instal, service or repair the units purchased.
- u. Removal of existing unit to be included and delivered to the SCM stores
- v. Back to back installation to be included.