



BA-PHALABORWA MUNICIPALITY

- BUDGET AND TREASURY –

- PROCUREMENT AND STORES -

TO : Prospective Service Provider
FROM : SCM/STORES
DATE : 26/08/2016
ENQUIRIES : STORES
TELEPHONE : 015 780 6362/61
REF : 128559

Kindly furnish this office with a written quotation for supply of goods/ services as detailed below. The quotation must be submitted on the letterhead of your Business and Brought to our offices/ emailed to MogofeN@ba-phalaborwa.gov.za or not later than 05/09/2016 at 12H00.

QUAN TITY	Description	PRICE/UNIT (Inc .VAT)	DELIVERY PERIOD
01	Gloves Pair of ultra-safe finger save Pu latex grip		
01	Gloves pair of ultra max finger save german latex grip		
01	Neon yellow / navy men's R10 goalkeeper sets		
01	Royal / Black men's Torino goalkeeper sets		
02	Sets of goalkeeper socks		

Please number your quotes (Your Ref no)

The following conditions will apply:

- Price (s) quoted must be valid for **at least thirty (30) days** from date of your offer.
- The municipality retains the prerogative to reject any quotes it deems to be excessive
- A firm delivery period must be indicated.
- Original Tax Clearance Certificate
- A service provider be registered with Ba-Phalaborwa database
- Registered with CIPRO (CK 1 or 2 document)
- BBBEE Certificate certified by a SANAS accredited institution.
- Fill in and Return the Declaration of Interest Form.
- CSD registration summary report

The municipality reserves a right not to appoint on the advertised



BA-PHALABORWA MUNICIPALITY

- BUDGET AND TREASURY –

- PROCUREMENT AND STORES -



BA-PHALABORWA MUNICIPALITY

- BUDGET AND TREASURY –

- PROCUREMENT AND STORES -

BID SPECIFICATIONS

BID DESCRIPTION: SUPPLY AND DELIVERY OF SINGLE AND THREE PHASE PRE-PAYMENT METERS

1. The prepayment meter must be a Split meter which shall consists of the following components:
 - a) Energy management Unit (EMU)
 - b) Consumer interface Unit (CIU)
2. Communication between consumer interface unit and energy management unit:
 - a) By means of power line carriers (PLC) technology.
 - b) MUST be of design that doesn't allow appliances or equipment to interfere with the communication of the meter.
3. **Energy management unit (EMU)**
 - a) The footprint of the energy management unit (metering unit) must be a compact meter (EMU) design, with DIN rail-mount or compact BS housing layout for single phase and compact BS housing for triple phase.
 - b) Rated voltage 230 Volts AC.
 - c) Operating voltage 230 volts (-20% to +15%)
 - d) Over voltage to withstand SABS (1524) 400 volts for 48 hours.
 - e) Basic current I_b – 20 Amps
 - f) Maximum continuous Current I_{max} . – (s/p)80 Amps and (t/p)100Amps
 - g) Measuring currency (SABS; IEC6 1036 Accuracy class) – Class 2 (approx. 2% from 0,1 I_b to I_{max}).
 - h) Rated frequency – 50 Hz
 - i) Power consumption / Burden - Voltage circuit < 3 Watts / 12 VA Current circuit < 2,5VA
 - j) Inherent voltage impulse withstand (BIL) – 6Kv 1,2/50 μ s
(No surge arrestor)With surge arrestor – Service rating – 5Ka (8/20 μ s waveform)
Withstand rating (2minutes) - 30Ka (8/20 μ s waveform) Insulation properties (1minute) – 2kVrms (Class 1) 4kV impulse (Class 1) 1,2/50 μ s waveform Over voltage 400 volts for 48 hours
 - k) Energy direction – Forward and reverse
 - l) Disconnecting Device Type :Single pole latching contactor Rated current 100 Amps Type: 3 pole latching contactor Rated current 100 Amps
 - m) Applicable specifications : (SABS) IEC 6 1036SABS 1524 NRS 009
 - n) Short circuit current : 2,4Ka



BA-PHALABORWA MUNICIPALITY

- BUDGET AND TREASURY –

- PROCUREMENT AND STORES -

3.1 Environmental Conditions:

- a) Operating temp. range : -10°C (+14°F) to +55°C (+131°F)
- b) Storage temp. range : -25°C (-13°F) to +70°C (+158°F)
- c) Relative humidity (IEC 6 1036) – annual mean 75% (Max. 95%)
- d) Degree of protection : IP 51

- 4. Total encryption method 20-Digit-STs
- 5. Communication circuitry: Up to 100 metres.
- 6. Sealing: Factory sealed with screw-seals or stainless steel wire ferrul seal.

ALL Energy meters will be programmed with 50 Units of Kwh before delivery to Ba-Phalaborwa Municipality.

7. Consumer interface Unit (CIU)

- a) The following must be printed on the consumer interface unit: This electrical unit is the property of the local supply authority. The use of it is subject to the local authority's conditions of supply.
- b) Keypad: 12 key international standard layout including "information" and "backspace" keys.
- c) Rate of consumption indicator (Pulse rate proportional to current rate of consumption).
- d) Diagnostic information: 20 additional meter parameters accessible via "information" key.
- e) Must be a user friendly consumer interface unit, making use of a clear language and must display all parameters of the meter including low credit warning, energy consumption and load contactor status.



BA-PHALABORWA MUNICIPALITY

- BUDGET AND TREASURY –

- PROCUREMENT AND STORES -

PRICE SCHEDULE

1. COMMUNICATION BETWEEN INTERFACE UNIT AND ENERGY MANAGEMENT UNIT BY MEANS OF POWER LINE CARRIER (PLC) TECHNOLOGY

1.1 Single phase split prepayment meter using power line carrier (PLC) Technology

DESCRIPTION	PRICE PER UNIT (VAT INCLUDED)	SABS Mark	Delivery Period	Settlement discount for 30 days:
1) Interface Unit (Remote Control)				
2) Energy Management Unit DIN RAIL MOUNTED (Metering Unit)				
Name of Manufacturer				
Total 1 & 2 (A)				

1.2 Three phase split prepayment meter using power line carrier (PLC) Technology

DESCRIPTION	PRICE PER UNIT (VAT INCLUDED)	SABS Mark	Delivery Period	Settlement discount for 30 days:
3) Interface Unit (Remote Control)				
4) Energy Management Unit COMPACT BS HOUSING (Metering Unit)				
Name of Manufacturer				
Totals 3 & 4 (B)				
Totals (A & B)				

NOTE: 1) PRICES WILL INCLUDE TRANSPORT AND DELIVERY AT BA-PHALABORWA MUNICIPALITY STORES.